



WPS Westwood Generation, LLC
45 Westwood Road, P.O. Box 312
Tremont, PA 17981

August 19, 2010

Diana Escher
Director, Air Protection Division
U.S. Environmental Protection Agency
1650 Arch Street
Philadelphia, PA 19103

RECEIVED
AUG 25 2010
3AP20

Dear Ms. Escher;

Westwood Generating Station Diesel Fire Pump - Initial Notification of Applicability

Attached please find Initial Notification of Applicability for the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (40CFR63 Subpart ZZZZ) for the Westwood Generating Station Diesel Fire Pump. The diesel fire pump has been used in the past for both emergency and non-emergency purposes. We plan to install an electric motor driven pump for non-emergency purposes during the next plant outage. After the electric motor driven pump is installed, the diesel engine will be used for emergency purposes only. This submittal is being made merely to comply with the Initial Notification requirements.

If you have any questions or comments, please contact Chris Waltman at (920) 433-2278 or via email at cswaltman@integrysgroup.com.

Sincerely,

A handwritten signature in black ink, which appears to read "John L. Oelbracht".

John L. Oelbracht
Plant Manager – Westwood Generating Station, LLC.

Cc Mark Wejksznier (PADEP)

Initial Notification of Applicability

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines

40 CFR Part 63 Subpart ZZZZ

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for
Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221112

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: WPS Westwood Generation, LLC

Facility name (if different): WPS Westwood Generating Station

Facility (physical location) address: 45 Westwood Road, Tremont, PA 17981

Owner name/title: John L. Oelbracht / Plant Manager

Owner/company address: WPS Westwood Generation, LLC
1716 Lawrence Drive, DePere, WI 54115

Owner telephone number: 570-695-3175 ext. 13

Owner email address: jloelbracht@integrysenergy.com

Contact name: Chris Waltman

Contact telephone number: 920-433-2278

Contact email address: cswaltman@integrysgroup.com

If the Operator information is different from the Owner, please provide the following:


Operator name/title: Same as above

Operator telephone number: Same as above

Operator email address: Same as above

The diesel fire pump has been used in the past for both emergency and non-emergency purposes. We plan to install an electric motor driven pump for non-emergency purposes during the next plant outage. After the electric motor driven pump is installed, the diesel engine will be used for emergency purposes only. This submittal is being made merely to comply with the Initial Notification requirements.

I hereby certify that the information presented herein is correct to the best of my knowledge.


(Signature)

August 19, 2010
(Date)

John L. Oelbracht / Plant Manager
(Name/title)

570-695-3175 ext.13
(Telephone No.)